



Septic Systems in a Special Flood Hazard Area

Criteria for Installing a Septic System in a Special Flood Hazard Area

Property owners must install and maintain:

- 1 A KDHE approved top lid concrete septic tank, plastic septic tank or an aerobic treatment tank. All tanks must have approved/accepted anchoring, due to additional weight from potential flood waters.
- 2 Adequate anchoring to keep the tank secure in the event of saturated soils in floodwater.
- 3 Follow any other criteria assigned by the local floodplain manager.
- 4 Do not cover the Septic system without an inspection by the Reno County Health Department's Environmental Staff. To contact, call 620-694-2900.

Examples:



For more information contact:

Reno County Health Department
209 West Second Street
Hutchinson, KS 67501
Phone: 620-694-2900
Fax: 620-694-2901
<http://www.renogov.org/>

